

Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

Product No.	Product Name	Standard	Rating	Wide	High	Test Report #	CertDate	ExpDate
411-H-1500.00	Lifestyle with HGP Vent Casement	101/I.S.2/A440-08	Class CW-PG50; Size Tested 35in x 73in Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infill/Exfil. Level=A3	35in	73in	ESP030123P.1Rev2	4/3/2019	1/15/2029
411-H-1500.01	Lifestyle with HGP Vent Casement	101/I.S.2/A440-11	Class CW-PG50; Size Tested 35in x 73in Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infill/Exfil. Level=A3	35in	73in	ESP030123P.1Rev2	4/3/2019	1/15/2029
411-H-1500.02	Lifestyle with HGP Vent Casement	101/I.S.2/A440-17	Class CW-PG50; Size Tested 35in x 73in Type-C; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infill/Exfil. Level=A3	35in	73in	ESP030123P.1Rev2	4/3/2019	1/15/2029
411-H-1500.03	Lifestyle with HGP Vent Casement	CSA A440 S1-09	Class CW-PG2400; Size Tested 889mm x 1854mm Type-C; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infill/Exfil. Level=A3	889mm	1854mm	ESP030123P.1Rev2	4/5/2019	1/15/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee* **John McFee, VP of Certification Programs, WDMA Hallmark**
By:  *Lucas L. Wenzel* **Lucas L. Wenzel, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com