

Hallmark® Certificate of Conformance and License (CCL)




Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
411-H-1501.00	Lifestyle with HGP Vent Awning	101/I.S.2/A440-08	Class CW-PG50; Size Tested 59in x 59in Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	59in	59in	ESP030123P.5Rev2	4/4/2019	2/7/2029
411-H-1501.01	Lifestyle with HGP Vent Awning	101/I.S.2/A440-11	Class CW-PG50; Size Tested 59in x 59in Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	59in	59in	ESP030123P.5Rev2	4/4/2019	2/7/2029
411-H-1501.02	Lifestyle with HGP Vent Awning	101/I.S.2/A440-17	Class CW-PG50; Size Tested 59in x 59in Type-AP; DP +50/-50 psf; Water Test Press 360Pa (7.52psf); Can. Air Infil/Exfil. Level=A3	59in	59in	ESP030123P.5Rev2	4/4/2019	2/7/2029
411-H-1501.03	Lifestyle with HGP Vent Awning	CSA A440 S1-09	Class CW-PG2400; Size Tested 1499mm x 1499mm Type-AP; DP +2400/-2400 Pa; Water Test Press 360Pa; Can. Air Infil/Exfil. Level=A3	1499mm	1499mm	ESP030123P.5Rev2	4/5/2019	2/7/2029

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com