



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-1219x914 (48x36)-AP Negative Design Pressure = -55 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	12220	PREMIUM VINYL (V-4500) ROTARY OPERATED AWNING (FIN) (PVC)(X)(OG)(INS GL) (MODIF)(ASTM)	<u>FRAME</u> 1219 mm x 914 mm (4'0" x 3'0")	<u>VENT</u> 1181 mm x 876 mm (3'10" x 2'10")


This Certification will expire **February 26, 2028 (extended from February 26, 2023 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **National Certified Testing Laboratories**

Report No.: **NCTL-310-4012**

Date of Report: **February 27, 2014**

Evaluated for Certification: **June 1, 2021**


Associated Laboratories, Inc.

Authorized for Certification: **June 1, 2021**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)