AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program

AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

| SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 **LC-PG50-913x1827 (36x72)-C** Negative Design Pressure = -55 psf				
COMPANY AND CODE	**CPD NO.**	**SERIES MODEL & PRODUCT DESCRIPTION**	**MAXIMUM SIZE TESTED**	
JELD-WEN Windows & Doors **Code: JW**	**16924**	**PREMIUM VINYL (V-4500) ROTARY OPERATED CASEMENT (FIN & FINLESS) (PVC)(X)(OG)(INS GL) (ASTM)**	**FRAME** 913 mm x 1827 mm (3'0" x 6'0")	**VENT** 876 mm x 1791 mm (2'10" x 5'10")

This Certification will expire **September 26, 2027 (extended from September 26, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **Intertek B&C**

    Report No.: **H5874.02-301-47**

    Date of Report: **October 6, 2017**

Evaluated for Certification: **May 12, 2020**

Associated Laboratories, Inc.

Authorized for Certification: **May 12, 2020**

Fenestration and Glazing Industry Alliance

A·L·I

(Validator / Operations Administrator)

ACP-04 (Rev. 2/20)