



AAMA CERTIFICATION PROGRAM
An FGIA Product Certification Program



AUTHORIZATION FOR PRODUCT CERTIFICATION

JELD-WEN Windows & Doors
P.O. Box 1329
Klamath Falls, OR 97601

Attn: Joshua Goossen

This authorization is based on the successful completion of tests, and the reporting to the AAMA Validator of the results of the tests by an AAMA Accredited Laboratory. The product information below will be added to the next update of the AAMA Certified Products Directory.

SPECIFICATION	RECORD OF PRODUCT TESTED			
AAMA/WDMA/CSA 101/I.S.2/A440-11 LC-PG50-3658x1829 (144x72)-C Negative Design Pressure = -55 psf				
COMPANY AND CODE	CPD NO.	SERIES MODEL & PRODUCT DESCRIPTION	MAXIMUM SIZE TESTED	
JELD-WEN Windows & Doors Code: JW	12482	PREMIUM VINYL (V-4500) ROTARY OPERATED QUAD CASEMENT (FIN & VINYL CLIPS) (PVC)(XXXX)(OG)(INS GL) (MODIF)(REINF)(ASTM)	FRAME 3658 mm x 1829 mm (12'0" x 6'0")	VENT 865 mm x 1790 mm (2'10" x 5'10")


This Certification will expire **October 31, 2027 (extended from October 31, 2022 per AAMA 103-19)** and requires validation until then by continued listing in the current AAMA Certified Products Directory.

Product Tested and Reported by: **National Certified Testing Laboratories**

Report No.: **SJW2014-037; ref. SJW2014-031 & SJW2013-243**

Date of Report: **April 28, 2014; March 14, 2014; December 2, 2013**

Evaluated for Certification: **May 12, 2020**


Associated Laboratories, Inc.

Authorized for Certification: **May 12, 2020**


Fenestration and Glazing Industry Alliance



(Validator / Operations Administrator)