

Hallmark® Certificate of Conformance and License (CCL)




Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
411-H-1490.35	Architect Series and Architect Series Reserve Sliding Patio Door	101/I.S.2/A440-11	Class LC-PG35; Size Tested 3029 mm x 3035 mm Type-SD; DP +35/-45 psf; Can. Air Infil/Exfil. Level=A3	3029 mm	3035 mm	ESP026730P.2 XO	12/1/2017	10/13/2027
411-H-1490.38	Architect Series and Architect Series Reserve Sliding Patio Door	ASTM E1996-14a/ ASTM E-1886-13a	DP +35/-45 psf, Missile D, Wind Zone 4	3029 mm	3035 mm	ESP026730P.ASTM Sliding Door	1/31/2018	10/13/2027
411-H-1490.39	Architect Series and Architect Series Reserve Sliding Patio Door	TAS 201/202/203-94	DP +35/-45 psf, Large Missile	3029 mm	3035 mm	ESP026730P.Sliding Door	2/1/2018	10/9/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  *John McFee, VP of Certification Programs, WDMA Hallmark*

By:  *Rhonda Schotz, Authorized Representative, AMS*

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com