

Hallmark® Certificate of Conformance and License (CCL)




Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
411-H-1490.10	Architect Series and Architect Series Reserve Sliding Patio Door	101/I.S.2/A440-11	Class LC-PG65; Size Tested 1810 mm x 2426 mm * Type-SD; DP +65/-65 psf; Water Test Press 470Pa (9.82psf); Can. Air Infil/Exfil. Level=A3	1810 mm	2426 mm	ESP024305P.6	5/9/2017	12/14/2026
411-H-1490.23	Architect Series and Architect Series Reserve Sliding Patio Door	ASTM E-1996 14/ASTM E-1886 13a	DP +65/-65 psf, Missile D, Wind Zone 4	1810 mm	2426 mm	ESP024305P.ASTM Sliding Door IMPACT	5/9/2017	12/29/2026
411-H-1490.24	Architect Series and Architect Series Reserve Sliding Patio Door	TAS 201/203-94	DP +65/-65 psf	1810 mm	2426 mm	ESP024305P DADE Sliding Door	5/12/2017	1/23/2027

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  **John McFee, VP of Certification Programs, WDMA Hallmark**

By:  **Rhonda Schotz, Authorized Representative, AMS**

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com