NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: DATE: CERTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:	<u>N1009851-R6</u> 04/21/2009 <u>Structural</u> <u>Provia</u> 1212-1 01/11/2021
REVISION DATE.	01/11/2021
	DATE: CERTIFICATION PROGRAM: COMPANY: CODE:

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION	
ProVia LLC	Series "Signet" Fiberglass	
2150 State Route 39	In-Swing or Out-Swing Double Door	
Sugarcreek, OH 44681	w/Two 20" Direct Set Sidelites & Transom	
	Configuration: O/OXXO Glazing: Insulating Glass (Tempered)	
	Frame: W-3061mm(120.5") H-2559mm(100.75") Panel: W-908mm(35.75") H-2108mm(83.00")	
	Sidelite: W-540mm(21.25") H-2172mm(85.50")	
	Transom: W-3061mm(120.50") H-387mm(15.25")	

SPECIFICATION

ASTM E283-04 ASTM E330-02/E331-00 PRODUCT RATING

Design Pressure: +40/-50 psf Qualifying Configurations: x/0x/x0/0xx/xx0/0xx0/0/x/0/0x0/0/xx/0/xx0/ 0/0xx/0/0xx0

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-110-11912-7/W-1422/W-1468/W-1978 February 28, 2025

Administrator's Signature:

Sh

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122