NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO: DATE: DATE: CENTIFICATION PROGRAM: COMPANY: CODE: REVISION DATE:	NI010431.01-R4 03/07/2011 Structural Provia 1212-1 02/09/2021
--	--

To verify that the "Notice of Product Certification" is valid, please visit <u>www.NAMICertification.com</u> to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC	Series "Signet" Embossed In-Swing
2150 State Route 39	or Out-Swing Glazed Double Door
Sugarcreek, OH 44681	w/Standard Panel Sidelites
	Configuration: OXXO Glazing: Insulating Glass (Tempered)
	Frame: W-2762mm(108.75") H-2477mm(97.50") Panel: W-908mm(35.75") H-2413mm(95.00")
	Sidelite DLO: W-170mm(7.00") H-1603mm(63.10")
	STP: Pos+3447 Pa(72.0 psf) Neg-3735 Pa(78.0 psf)

PRODUCT RATING
Design Pressure: +48/-52 psf Qualifies Configurations: X/O/XX/OX/XO/OXO/OXX/XXO/OXXO

Product Tested By: Report No: Expiration Date: National Certified Testing Laboratories NCTL-110-13337-1/W-1479/W-1978 September 30, 2022

Sh

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124 Fax: (804) 684-5122