

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010431.02-R3
DATE: 03/07/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Provia
CODE: 1212-1
REVISION DATE: 01/11/2021

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
ProVia LLC 2150 State Route 39 Sugarcreek, OH 44681	Series "Signet" Embossed In-Swing or Out-Swing Glazed Double Door w/Direct-Set Fixed Panel Sidelites Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-2915mm(114.75") H-2477mm(97.50") Panel: W-908mm(35.75") H-2413mm(95.00") Direct-Set Sidelite DLO: W-394mm(15.50") H-2413mm(95.00") STP: Pos+3447 Pa(72.0 psf) Neg-3735 Pa(78.0 psf)

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02	Design Pressure: +40/-50 psf Qualifies Configurations: X/O/XX/OX/XO/OXO/OXX/XXO/OXXO

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-13337-1/W-1479/W-1978
Expiration Date: September 30, 2022

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122