

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011595.12-R3  
**DATE:** 07/01/2013  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** ProVia Door  
**CODE:** 1212-1  
**REVISION DATE:** 01/11/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>ProVia LLC</b> <b>2150 State Route 39</b> <b>Sugarcreek, OH 44681</b>	<b>Fiberglass In-Swing</b> <b>Glazed Side Hinged Door</b> <b>w/Sidelites</b>  Configuration: OXO  Glazing: Insulating Glass (Tempered)  Frame: W-2598mm(102.32") H-2478mm(97.59")  Panel: W-908mm(35.75") H-2411mm(94.94")

SPECIFICATION	PRODUCT RATING
<b>ASTM E330-02</b>	<b>Design Pressure: +45/-50 psf</b> Qualifies Configurations: O/X/OX/XO/OXO

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-15660-1/NCTL-110-13337-1/NCTL-110-15650-4/  
NCTL-110-15651-4/W-1598/W-1978  
Expiration Date: **December 31, 2024**

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S.M.D.', is written over the signature line.

**NATIONAL ACCREDITATION &  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122