



LISTING INFORMATION OF Air Louvers VLF-IGHRC Vision Frame

SPEC ID: 15681

Air Louvers, Inc.
6285 Randolph St.
Commerce, CA 90040

This report is for the exclusive use of Intertek's Client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this report. Only the Client is authorized to permit copying or distribution of this report and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek. The observations and test results in this report are relevant only to the sample tested. This report by itself does not imply that the material, product, or service is or has ever been under an Intertek certification program.

WINDSTORM RESISTANT PRODUCTS & COMPONENTS

Model#	Configuration	Min. Door Size	Door Stiffness
VLF-IGHRC	Single Out-Swing	48" by 84"	Class I
Max. Overall Size		Ratings (D.L.)	
Width (in)	Height (in)	Structural (PSF)	Impact (ft-lb)
31-3/4	62	+/-70	350Missile Level "D"

- * Vision Frame must be installed in a listed windstorm resistant door.
- * All doors/walls/components must be rated and listed accordingly.

<u>Attribute</u>	<u>Value</u>
Criteria	ASTM E330 (2002)
Criteria	ASTM E1886 (2002)
Criteria	ASTM E1996 (2003)
Criteria	ANSI A250.13 (2003)
CSI Code	08 11 00 Metal Doors and Frames
DP Rating (psf)	70
Hurricane Impact Load Rating ft-lb	350
Impact Missile Level	Level D
Intertek Services	Certification
Listing Section	DOOR LIGHT FRAMES/KITS
Report Number	3116736-002
Spec ID	15681
Swing	Out swing
Swing	Single Swing