NOTICE OF PRODUCT CERTIFICATION I



CERTIFICATION NO: NI011912-R10

DATE: 03/19/2014

CERTIFICATION PROGRAM: Structural

COMPANY: <u>JELD-WEN</u>

CODE: <u>1822-1</u> REVISION DATE: <u>05/01/2019</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN	JELD-WEN "Design Pro/Smooth Pro/Studio"
3737 Lakeport Boulevard	Fiberglass Glazed In-Swing or Out-Swing
Klamath Falls, OR 97601	Side-Hinged Doors w/Glazed Sidelites
	Configuration: OXXO Glazing: Insulating Glass (Tempered)
	IS Frame: W-3778mm(148.75") H-2081mm(81.93")
	OS Frame: W-3778mm(148.75") H-2063mm(81.25")
	Panel: W-908mm(35.75") H-2012mm(79.25")
	DLO: W-606mm(23.87") H-1587mm(62.50")

SPECIFICATION	PRODUCT RATING
ASTM E283-04/E330-02 TAS 202-94 AAMA 1304-02	Design Pressure: +50/-50 psf Qualifies Configurations: OXX/XXO/OXXO

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-3918-01/NCTL-210-3918-02/NCTL-210-3924-02/NCTL-210-3925-03/SJW2013-195/SJW2013-

241/SJW2013-242/SJW2013-208-TAS/SJW2013-209-TAS/SJW2013-251/SJW2013-252/SJW2013-

253/SJW2014-032/NCTL-210-3930-01/NCTL-210-3930-02/SJW2014-069/SJW2014-079/W-1665/W-1706/W-1665/W-1

1783/W-1799/W-1861/W-1899/W-1904

Expiration Date: March 30, 2026

Administrator's Signature:

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072

Tel: (804) 684-5124 Fax: (804) 684-5122