

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011921.01-R10
DATE: 03/26/2014
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 05/21/2019

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|---|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | JELD-WEN "Design Pro/Smooth Pro/Studio" Fiberglass Glazed In-Swing or Out-Swing Side-Hinged Door Configuration: X Glazing: Insulating Glass (Tempered) IS Frame: W-952mm(37.50") H-2487mm(97.93") OS Frame: W-952mm(37.50") H-2466mm(97.12") Panel: W-908mm(35.75") H-2419mm(95.25") DLO: W-606mm(23.87") H-1995mm(78.56") |

| SPECIFICATION | PRODUCT RATING |
|---------------------|--|
| ASTM E330-02 | Design Pressure: +50/-50 psf Qualifies Configurations: X |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3918-01/SJW2013-231/SJW2013-251/SJW2013-252/SJW2013-253/NCTL-210-3925-03/SJW2014-032/NCTL-210-3930-01/NCTL-210-3930-02/SJW2014-068/SJW2014-071/SJW2014-069/SJW2014-079/W-1672/W-1697/W-1783/W-1799/W-1861/W-1879/W-1899/W-1904
Expiration Date: **March 30, 2026**

A handwritten signature in black ink, appearing to be "S. D.", written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122