

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI012201.03-R1  
**DATE:** 07/25/2017  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Quaker  
**CODE:** 031-1  
**REVISION DATE:** 02/20/2018

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Quaker Window Products</b> <b>504 Highway 63 South</b> <b>Freeburg, MO 65035</b>	<b>Series" Emerge E700 Slider"</b> <b>Aluminum Horizontal Sliding Window</b> <b>w/Angle Clip or Nail Fin Installation</b>  Configuration: OX Glazing: IG-Interior-3/16" Annealed Glass/ Exterior-Laminate-1/8" Annealed Glass/0.090" PVB Interlayer by Solutia/1/8" Annealed Glass  Frame: W-1829mm(72") H-1676mm(66") Panel: W-908mm(35.75") H-1559mm(61.38") DLO: W-822mm(32.38") H-1492mm(58.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>ASTM E1886-05/E1996-12</b>	<b>Class CW-PG50 1829 x 1676 (72 x 66)-HS</b> <b>Design Pressure: ±2400 Pa (50 psf)</b> Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf) Canadian Air Infiltration/Exfiltration Level: A3 <b>Wind Zone 4-Missile Level D</b>

Product Tested By: Architectural Testing, Inc.  
Report No: D7474.01-201-44/D7474.02-201-44/W-1825  
Expiration Date: **April 30, 2028**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122