

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011678-R1  
DATE: 10/08/2013  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 06/10/2017

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>"8300 Premium Atlantic Vinyl Fixed Window (Non-Impact)"</b> <b>Vinyl Fixed Window</b> <b>w/Fin or Flange Installation</b>  Configuration: O Glazing: Insulating Glass (Annealed)  Frame: W-1323mm(52.12") H-1905mm(75.00") DLO: W-1231mm(48.50") H-1816mm(71.50")

SPECIFICATION	PRODUCT RATING
<b>TAS 202-94</b>	<b>Design Pressure: 2633 Pa (55 psf)</b> <b>Negative Design Pressure: 2633 Pa (55 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3911-01  
Expiration Date: August 30, 2025

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122