

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011567.02-R2
DATE: 05/23/2013
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 01/13/2017

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|---|--|
| JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601 | "Premium Atlantic Vinyl Single Hung (8100)" Impact Rated Vinyl Single Hung Window (Fin & Flange Installation) Configuration: O/X Glazing: IG-1/8" Annealed Glass/Laminate- 1/8" Annealed Glass/0.090" SentryGlas® Plus Interlayer by DuPont/1/8" Annealed Glass or IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" PVB by DuPont/1/8" Annealed Glass Frame: W-1324mm(52.13") H-1905mm(75") Sash: W-1254mm(49.38") H-946mm(37.25") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------|--|
| TAS 201/202/203-94 | Design Pressure: +50/-60 psf Large Missile Impact Rated |

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3874-1
Expiration Date: **April 30, 2025**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122