

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009663-R5
DATE: 10/23/2008
CERTIFICATION PROGRAM: Structural
COMPANY: Quaker
CODE: 031-1
REVISION DATE: 09/16/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Quaker Window Products 504 Highway 63 South Freeburg, MO 65035	Series "K200/E200" Thermally-Broken Aluminum Fixed Window Configuration: O Glazing: Insulating Glass (Annealed) Frame: W-1632mm(64") H-1803mm(71") DLO: W-1473mm(58") H-1734mm(68.75")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	Class CW-PG50 1632 x 1803 (64 x 71)-FW FW-HC50 1632 x 1803 (64 x 71) Design Pressure: ±2400 Pa (50 psf) Positive Design Pressure: 2880 Pa (60 psf) Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 360 Pa (7.52 psf)

Product Tested By: Architectural Testing, Inc.
Report No: 82361.01-801-47/W-1536/W-1960
Expiration Date: April 30, 2026

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122