

Hallmark® Certificate of Conformance and License (CCL)




Pella Corporation
102 Main Street
Pella, IA 50219

Mfr ID: 411
For more Information visit www.amscert.com
Website: www.pella.com
TEL: 641-621-6096

<i>Product No.</i>	<i>Product Name</i>	<i>Standard</i>	<i>Rating</i>	<i>Wide</i>	<i>High</i>	<i>Test Report #</i>	<i>CertDate</i>	<i>ExpDate</i>
411-H-1221.10	Pella Architect Reserve Double Hung, Wood, Model 5	101/I.S.2/A440-17	Class CW-PG30; Size Tested 1403 x 2438 mm (55.25 x 96 in) Type-H; DP +30/-35 psf; Water Test Press 220Pa (4.59psf); Can. Air Infil/Exfil. Level=A3	1403mm	2438mm	ESP038732P.8	4/12/2023	10/25/2033
411-H-1221.11	Pella Architect Reserve Double Hung, Wood, Model 5	101/I.S.2/A440-11	Class CW-PG30; Size Tested 1403mm x 2438 mm (55.25 x 96 in) Type-H; DP +30/-35 psf; Water Test Press 220Pa (4.59psf); Can. Air Infil/Exfil. Level=A3	1403mm	2438mm	ESP038732P.8	4/12/2023	10/25/2033

WDMA and AMS HEREBY CERTIFY that the aforesaid Company ("Licensee"), at its participating manufacturing plant(s), is licensed to use the WDMA Registered Hallmark on product lines that have been manufactured in accordance with the indicated standards. It is further certified that the plant(s), facilities, quality control procedures, methods, and processes of Licensee have been inspected, and are subject to regular follow-up inspection and test. It is further certified that samples of the product set forth above were tested and found to comply with the standards.

By:  John McFee, VP of Certification Programs, WDMA Hallmark

By:  Lucas L. Wenzel, Authorized Representative, AMS

Program Sponsor:
Window and Door Manufacturers Assoc
330 N. Wabash Avenue, Suite 2000
Chicago, IL 60611
TEL (312)673-4828 www.wdma.com

Program Administrator:
Administrative Management Systems, Inc.
PO Box 730, 205 West Main
Sackets Harbor, NY 13685
TEL (315)646-2234 staff@amscert.com