

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO:	<u>NI006255-R9</u>
DATE:	<u>10/14/2005</u>
CERTIFICATION PROGRAM:	<u>Structural</u>
COMPANY:	<u>JELD-WEN</u>
CODE:	<u>1822-1</u>
REVISION DATE:	<u>05/13/2019</u>

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>JELD-WEN</p> <p>3737 Lakeport Boulevard</p> <p>Klamath Falls, OR 97601</p>	<p style="text-align: center;">Series "Contour Premium Steel Door"</p> <p style="text-align: center;">Double In-Swing/Out-Swing Steel Wood-Edge Entry Doors w/ODL Impact Glass or ODL Allen Frame and Endura Ultimate Hurricane Astragal</p> <p style="text-align: center;">Configuration: XX Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1880mm(74") H-2108mm(83")</p> <p>Panel: W-940mm(37") H-2007mm(79")</p> <p>DLO: W-559mm(22") H-1626mm(64")</p>

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +60/-60 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-210-3195-1/SJW2011-070/W-1556/W-1565/W-1897
 Expiration Date: **September 30, 2027**

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Fax: (804) 684-5122