

# NOTICE OF PRODUCT CERTIFICATION



**Company:** JELD-WEN Exterior Doors  
3737 Lakesport Drive  
Klamath Falls, OR 97601

**Certification No.:** NI011082-R3  
**Certification Date:** 05/01/2012  
**Expiration Date:** 08/31/2027  
**Revision Date:** 05/13/2019

**Product:** “Energy Saver/Contour” Opaque Wood-Edge Steel Door w/ or w/o Sidelite (wood frame)

**Specification:** TAS 201/202/203-94

The “Notice of Product Certification” is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI’s Certified Product Listing at [www.Namicertification.com](http://www.Namicertification.com). NAMI’s Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Water Test Pressure	Missile Impact Rated	Test Report Number Drawing Number & Comments
X Single	O/S	Opaque	3’2” x 6’10”	+66/-70	10.0 psf	Yes	CTLA-696W/W-1897 Max Panel Size: 3’0” x 6’8” Installation Details: S-2104 (1-8)
OX/XO Single w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	4’5” x 6’10”	+66/-70	10.0 psf	Door-Yes Sidelite-No	CTLA-696W/W-1897 Max Panel Size: 3’0” x 6’8” Sidelite DLO: 6” x 5’3” (1/8” Tempered Glass) Installation Details: S-2104 (1-8)
OXO Single w/Sidelites	O/S	Door-Opaque Sidelites-Glazed	5’10” x 6’10”	+66/-70	10.0 psf	Door-Yes Sidelites-No	CTLA-696W/W-1897 Max Panel Size: 3’0” x 6’8” Sidelite DLO: 6” x 5’3” (1/8” Tempered Glass) Installation Details: S-2104 (1-8)
XX Double	O/S	Doors-Opaque	6’3” x 6’10”	+57/-57	8.55 psf	Doors-Yes	CTLA-696W/W-1897 Max Panel Size: 3’0” x 6’8” Installation Details: S-2104 (1-8)
OXXO Double w/Sidelites	O/S	Doors-Opaque Sidelites-Glazed	8’11” x 6’10”	+57/-57	8.55 psf	Doors-Yes Sidelites-No	CTLA-696W/W-1897 Max Panel Size: 3’0” x 6’8” Sidelite DLO: 6” x 5’3” (1/8” Tempered Glass) Installation Details: S-2104 (1-8)

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072

Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: \_\_\_\_\_