

NOTICE OF PRODUCT CERTIFICATION



Company: JELD-WEN Doors
 3737 Lakeport Drive
 Klamath Falls, OR 97601

Certification No.: NI012740-R1
Certification Date: 04/17/2012
Expiration Date: 04/30/2028
Revision Date: 05/14/2019

Product: 24 Ga. Steel Wood Edge Impact Rated Opaque Doors w/ & w/o Impact & Non-Impact Rated Glazed Sidelites (w/wood frame unless specified)

Specification: TAS 201-94/202-94/203-94

The "Notice of Product Certification" is only valid if the NAMI Certification Label has been applied to the product as described within this document. The certification label represents product conformity to the applicable specification and that all certification criteria has been satisfied. This product has been approved for listing within NAMI's Certified Product Listing at www.Namicertification.com. NAMI's Certification Program is accredited by The American National Standards Institute (ANSI).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number Drawing Number & Comments
XX Double	I/S	Opaque	6'2" x 8'2"	+45/45 psf	Yes	NCTL-210-3801-1/FL 1803 Max Panel Size: 3'0" x 8'0" Installation Details: JW072012FL
XX Double	O/S	Opaque	6'2" x 8'1"	+45/45 psf	Yes	NCTL-210-3801-1/FL 1803 Max Panel Size: 3'0" x 8'0" Installation Details: JW072012FL
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	8'9" x 8'2"	+45/45 psf	Door-Yes Sidelite-No	ATI-65888.01-301-18/NCTL-210-3801-1/ CTLA 697WA/FL 1803 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 7" x 6'7" Glazing: IG- 1/8" Tempered w/ LVL DB Jamb Mullions Installation Details: JW072012FL
OXXO Double w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	8'9" x 8'1"	+45/45 psf	Door-Yes Sidelite-No	ATI-65888.01-301-18/75771.01-301-18/NCTL-210-3801-1/ CTLA 697WA/FL 1803 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 7" x 6'7" Glazing: IG- 1/8" Tempered w/ LVL DB Jamb Mullions Installation Details: JW072012FL

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
 Tel: (804) 684-5124/Fax: (804) 684-5122

NAMI AUTHORIZED SIGNATURE: _____

A handwritten signature in black ink, appearing to be 'Shelby' or similar, written over a horizontal line.