

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006255.02-R4
DATE: 06/23/2011
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 104-3
REVISION DATE: 05/05/2015

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	Series "Contour Premium Steel Door" Double In-Swing/Out-Swing Steel Wood-Edge Entry Doors w/ODL Impact Allen Frame and Endura Ultimate Hurricane Astragal Configuration: XX Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/0.090" Solutia Interlayer/1/8" Annealed Glass Frame: W-1880mm(74") H-2083mm(82") Panel: W-927mm(36.5") H-2013mm(79.25") DLO: W-559mm(22") H-1626mm(64")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	In-Swing (I/S) Design Pressure: +60/-65 psf I/S Water Resistance Test Pressure: 137 Pa (2.86 psf) Out-Swing (O/S) Design Pressure: +65/-60 psf O/S Water Resistance Test Pressure: 467 Pa (9.75 psf) Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3195-1/SJW2011-050/W-1486/W-1556/W-1564
Expiration Date: June 30, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124
Fax: (804) 684-5122