

NOTICE OF PRODUCT CERTIFICATION



Company: JELD-WEN Doors
 3737 Lakeport Drive
 Klamath Falls, OR 97601

Certification No.: NI012740-R3
Certification Date: 04/17/2012
Expiration Date: 04/30/2028
Revision Date: 05/09/2022

Product: 24 Ga. Steel Wood Edge Impact Rated Opaque Doors w/ & w/o Impact & Non-Impact Rated Glazed Sidelites (w/wood frame unless specified)

Specification: TAS 201-94/202-94/203-94

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

Configuration	Inswing or Outswing	Glazed or Opaque	Maximum Size	Design Pressure Pos/Neg	Missile Impact Rated	Test Report Number Drawing Number & Comments
XX Double	I/S	Opaque	6'2" x 8'2"	+45/45 psf	Yes	NCTL-210-3801-1/FL 1803/W-1905/W-2025 Max Panel Size: 3'0" x 8'0" Installation Details: JW072012FL
XX Double	O/S	Opaque	6'2" x 8'1"	+45/45 psf	Yes	NCTL-210-3801-1/FL 1803/W-1905/W-2025 Max Panel Size: 3'0" x 8'0" Installation Details: JW072012FL
OXXO Double w/Sidelites	I/S	Door-Opaque Sidelite-Glazed	8'9" x 8'2"	+45/45 psf	Door-Yes Sidelite-No	ATI-65888.01-301-18//NCTL-210-3801-1/ CTLA 697WA/FL 1803/W-1905/W-2025 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 7" x 6'7" Glazing: IG- 1/8" Tempered w/ LVL DB Jamb Mullions Installation Details: JW072012FL
OXXO Double w/Sidelites	O/S	Door-Opaque Sidelite-Glazed	8'9" x 8'1"	+45/45 psf	Door-Yes Sidelite-No	ATI-65888.01-301-18/75771.01-301-18/NCTL-210-3801-1/ CTLA 697WA/FL 1803/W-1905/W-2025 Max Panel Size: 3'0" x 8'0"/Daylight Opening: 7" x 6'7" Glazing: IG- 1/8" Tempered w/ LVL DB Jamb Mullions Installation Details: JW072012FL

National Accreditation & Management Institute, Inc./4794 George Washington Memorial Highway/Hayes, VA 23072
 Tel: (804) 684-5124/nami@namiinc.com

NAMI AUTHORIZED SIGNATURE: _____