



Impact Performance Certification Authorization Report

Stergis Windows and Doors Inc

79 Walton Street
Attleboro, MA 02703, USA

Certification ID:	4-8002
Company Code:	004
Certification Date:	7/27/2022
Revision No:	0
Revision Date:	7/27/2022
Expiration Date:	7/27/2026

Product Rating Information:

Model:	5000 Series Impact Single Hung SH-93			
Operator Type:	H			
Configuration:	All/EM, GS - 5/16" Ann Lami IG			
Referenced Standard:	ASTM E1886-05, ASTM E1996-06			
Product Rating:	Missile Level D, Wind Zone 3, DP +/-75, 54x84			
Rated Dimensions:	Max Width:	54 in	Max Height:	84 in
Linked Structural CARs:	8001			

Qualifying Test information:

Test Report No:	ATI-A9630.02-501-44
Test Report Expiration:	7/27/2026

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at www.keystonecerts.com

Authorized By:



Keystone Certifications, Inc.
145 Limekiln Rd, Suite 100B
New Cumberland, PA 17070
Phone: 717-932-8500



Impact Performance Certification Authorization Report

Revision History

Rev #	Date	Description
0	7/27/2022	Initial Issuance.