



# Impact Performance Certification Authorization Report

## Stergis Windows and Doors Inc

79 Walton Street  
Attleboro, MA 02703, USA

<b>Certification ID:</b>	4-211
<b>Company Code:</b>	004
<b>Certification Date:</b>	11/26/2008
<b>Revision No:</b>	1
<b>Revision Date:</b>	9/7/2021
<b>Expiration Date:</b>	9/27/2024

### Product Rating Information:

<b>Model:</b>	Stormgate NC Impact Casement			
<b>Operator Type:</b>	C			
<b>Configuration:</b>	All/J/Snub, GS-5/16" Lami IG			
<b>Referenced Standard:</b>	ASTM E1886/E1996-02			
<b>Product Rating:</b>	Missile Level D, Wind Zone 4, DP +/- 50, 37x75			
<b>Rated Dimensions:</b>	<b>Max Width:</b>	37 in	<b>Max Height:</b>	75 in
<b>Linked Structural CARs:</b>	112-186.0			

### Qualifying Test information:

<b>Test Report No:</b>	CTLA 1559W-1-R
<b>Test Report Expiration:</b>	9/27/2024

This Certification Authorization Report (CAR) is issued by Keystone Certifications, Inc. (KCI) after full validation review, and is based on a standardized evaluation of the product conducted by an independent accredited laboratory in accordance with the specified referenced standard. Actual fenestration product performance may vary based on many factors, including installation, condition of the wall/roof substrate and the age of the product and installation components.

This report indicates the product is eligible for the application of Keystone Certification Program certification labels. Licensee stipulates in affixing certification labels to products, that those products are representative of the specimen evaluated and documented for certification authorization. Only products bearing such a certification label shall be considered certified. The information in this report can be verified at [www.keystonecerts.com](http://www.keystonecerts.com)

Authorized By:



Keystone Certifications, Inc.  
145 Limekiln Rd, Suite 100B  
New Cumberland, PA 17070  
Phone: 717-932-8500



# Impact Performance Certification Authorization Report

## Revision History

Rev #	Date	Description
0	11/26/2008	Initial Issuance
1	9/7/2021	Granted 3 Year Extension