

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009020.02-R3
DATE: 04/13/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 08/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "FWI 1000" Aluminum Impact Rated Single Hung Window Configuration: O/X Glazing: Laminate-1/8" Annealed Glass/ 0.090" Safety-Plus II Interlayer/ 1/8" Annealed Glass Frame: W-1349mm(53.13") H-2438mm(96") Sash: W-1281mm(50.44") H-1226mm(48.25")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: ±2873 Pa (60 psf) Large Missile Impact Rated

Product Tested By: Fenestrtrion Testing Laboratory, Inc.
Report No: 07-311/5417/02
Expiration Date: September 30, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com