

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010670.02
DATE: 09/20/2023
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<p>Eastern Architectural Systems</p> <p>16341 Domestic Avenue</p> <p>Ft. Myers, FL 33913</p>	<p style="text-align: center;">Series "FWI 1000" Aluminum</p> <p style="text-align: center;">Impact Rated Single Hung Window</p> <p style="text-align: center;">Configuration: O/X</p> <p style="text-align: center;">Glazing: Mono: 1/8" Annelaed Glass/0.090" PVB Dupont Interlayer/1/8" Annealed Glass Or IG: Laminate-1/8" Annelaed Glass/1/8" Annealed Glass/0.090" PVB Dupont Interlayer/1/8" Annealed Glass</p> <p>Frame: W-1349mm(53.13") H-1981mm(78")</p> <p>Sash: W-1257mm(49.50") H-995mm(39.19")</p> <p>DLO: W-1248mm(49.13") H-916mm(36.06")</p>

SPECIFICATION	PRODUCT RATING
<p>TAS 201/202/203-94</p>	<p>Design Pressure: ±3840 Pa (±80 psf) Water Penetration Resistance Test: 580 Pa (12.00 psf) Large Missile Impact Rated</p>

Product Tested By: Blackwater Technical Services Inc.
 Report No: BT-EAS-23-003
 Expiration Date: September 30, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com