

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI009021.01-R5  
**DATE:** 04/13/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>16341 Domestic Avenue</b> <b>Ft. Myers, FL 33912</b>	<b>Series "FD-8100" Aluminum</b> <b>Impact Rated Sliding Glass Door</b>  Configuration: OXXXX  Glazing: Monolithic-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG - 3/16" Tempered Glass/3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass  Frame: W-5994mm(236") H-3048mm(120")  Panel: W-1257mm(49.5") H-2998mm(118")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b> <b>TAS201/202/203-94</b> <b>ASTM E1886-02/E1996-02</b>	<b>SD-C90 5994 x 3048 (236 x 120)</b> <b>Design Pressure: +90/-90 psf</b> <b>Large Missile Impact Rated</b> <b>Wind Zone 4-Missile Level D</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3407-1 & 210-3407-1A/W-2064  
Expiration Date: May 31, 2027

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@naminc.com](mailto:nami@naminc.com)

NOPC-03/30/2023