

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009021.03-R6
DATE: 04/14/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "FD-8100-NI" Aluminum Sliding Glass Pocket Door Configuration: OXXXX Glazing: Monolithic (Tempered) Frame: W-5994mm(236") H-3048mm(120") Panel: W-1257mm(49.5") H-2998mm(118")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-C70 5994 x 3048 (236" x 120")

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3754-2 (Specimen 2)
Expiration Date: May 31, 2027

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023