

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI009044.02-R3
DATE: 12/10/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "90° FD8100-LMI" Impact Rated 90 Degree Aluminum Sliding Glass Door Configuration: XXXXXXXXX Four Track Glazing: Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass Frame: W-6096mm(240") W-6096mm(240") 3048mm(120") Panel: W-1257mm(49.5") H-2998mm(118.03")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 TAS 201/202/203-94 ASTM E1886-02/E1996-02	SD-C44 6096 x 6096 x 3048 (240 x 240 x 120) Design Pressure: +44/-44 psf Wind Zone 4-Missile Level D Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3755-1/NCTL-210-3755-1A/W-1533
Expiration Date: May 31, 2027

Administrator's Signature: 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124

Email: nami@namiinc.com