NOTICE OF PRODUCT CERTIFICATION

CERTIFICATION NO:	**NI009044.03-R3**
DATE:	**12/10/2012**
CERTIFICATION PROGRAM:	**Structural**
COMPANY:	**Eastern**
CODE:	**1783-1**
REVISION DATE:	**10/16/2023**

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems **10030 Bavaria Road** **Ft. Myers, FL 33913**	**Series "90º FD8100-LMI" Impact Rated** **90 Degree Aluminum Sliding Glass Door** Configuration: XXXXXXXX Four Track Glazing: Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass or IG-3/16" Heat Strengthened Glass/ Laminate-3/16" Heat Strengthened Glass/0.100" Solutia Interlayer/3/16" Heat Strengthened Glass Frame: W-6096mm(240") W-6096mm(240") 2794mm(110") Panel: W-1257mm(49.5") H-2699mm(106.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05 **TAS 201/202/203-94** **ASTM E1886-02/E1996-02**	**SD-C60 6096 x 6096 x 2794 (240 x 240 x 110)** **Design Pressure: +60/-60 psf** **Wind Zone 4-Missile Level D** **Large Missile Impact Rated**

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3755-1/NCTL-210-3755-1A/W-1533
Expiration Date: **May 31, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Email: nami@namiinc.com