NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010633.01-R3

DATE: 02/15/2012

CERTIFICATION PROGRAM: Structural

COMPANY: <u>Eastern</u>

CODE: 1783-1

REVISION DATE: <u>11/10/2023</u>

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|-------------------------------|---------------------------------------------------|
| Eastern Architectural Systems | Series "135° FD8100" Aluminum |
| 16341 Domestic Avenue | Sliding Glass Pocket Door |
| Ft. Myers, FL 33912 | Configuration: XXXXXXXX Four Track |
| | Glazing: Insulating Glass (Tempered) |
| | |
| | Frame: W-4877mm(192") W-4877mm(192") 3048mm(120") |
| | Panel: W-1257mm(49.5") H-2998mm(118.03") |

| SPECIFICATION | PRODUCT RATING |
|---------------------------------|---------------------------------------------|
| AAMA/WDMA/CSA 101/I.S.2/A440-05 | SD-C50 4877 x 4877 x 3048 (192 x 192 x 120) |
| TAS 202-94 | Design Pressure: +50/-50 psf |

Product Tested By: National Certified Testing Laboratories

Report No: NCTL-210-3757-1/NCTL-210-3757-1A/W-1505

Expiration Date: **December 31, 2027**

Administrator's Signature: ___

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway Hayes, VA 23072 Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023