

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011134.03-R5
DATE: 06/08/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	Series "623" Vinyl Fin Frame or Equal Leg Frame Non-Impact Sliding Glass Door Glazing: Insulating Glass (Tempered) Frame: W-4877mm(192") H-2438mm(96") Panel: W-1243mm(48.93") H-2369mm(93.25") DLO: W-1040mm(40.93") H-2165mm(85.25")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	SD-C50 4877 x 2438 (192 x 96) Design Pressure: 2400 Pa (50 psf) Negative Design Pressure: 2400 Pa (50 psf) Water Penetration Resistance Test Pressure: 362 Pa (7.5 psf)

Product Tested By: Element Materials Technology
Report No: ESP009160P-5/ESP009160P-7
Expiration Date: April 30, 2027

Administrator's Signature: _____


NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023