

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010656-R4
DATE: 05/24/2011
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 11/15/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "2456" Vinyl Impact Fixed Window Configuration: O Glazing: IG-3/16" Annealed Glass/ Laminate-3/16" Annealed Glass/0.075" Sea Storm Solutia/3/16" Annealed Glass or 1/8" Annealed Glass/ Laminate-3/16" Annealed Glass/0.090" Kuraray PVB Interlayer/3/16" Annealed Glass OR 3/16" Annealed Glass/0.090" Kuraray PVB Interlayer/3/16" Annealed Glass/3/16" Annealed Glass Frame: W-1626mm(64") H-2134mm(84") DLO: W-1495mm(58.88") H-2003mm(78.88")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	FW-C80 1626 x 2134 (64 x 84)

Product Tested By: Architectural Testing, Inc.
Report No: 68098.03-701-47/W-2097
Expiration Date: **September 30, 2027**

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023