

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011878.01-R4  
DATE: 03/02/2014  
CERTIFICATION PROGRAM: Structural  
COMPANY: Eastern  
CODE: 1783-1  
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>10030 Bavaria Road</b> <b>Ft. Myers, FL 33913</b>	<b>Series "176.000" Vinyl Fin Frame</b> <b>Impact-Rated Fixed Window</b>  Configuration: O  Glazing: IG-3/16" Heat Strengthened Glass/Laminate- 1/8" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/1/8" Heat Strengthened Glass  Frame: W-1828mm(72") H-1600mm(63")  DLO: W-1708mm(67.25") H-1479mm(58.25")

SPECIFICATION	PRODUCT RATING
<b>ASTM E1886-05/E1996-09</b> <b>TAS 201/202/203-94</b> <b>AAMA-506-11</b>	<b>Design Pressure: ±3830 Pa (80 psf)</b> <b>Wind Zone 4-Missile Level D</b> <b>Large Missile Impact Rated</b> A440-05 Rating: <b>FW-C90 1829 x 1600 (72 x 63)</b> A440-08/11 Rating: <b>CW-PG100 1829 x 1600 (72 x 63)-FW</b> Water Penetration Resistance Test Pressure: 718 Pa(15.0 psf)

Product Tested By: Element Materials Technology  
Report No: ESP011976P-1/ESP011976P-1D  
Expiration Date: January 31, 2027

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072

Tel: (804) 684-5124

Email: [nami@namiinc.com](mailto:nami@namiinc.com)

NOPC-03/30/2023