

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011881.01-R4
DATE: 03/02/2014
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 10030 Bavaria Road Ft. Myers, FL 33913	Series "176.000" Vinyl Flange Frame Impact-Rated Fixed Window Configuration: O Glazing: IG-3/16" Heat Strengthened Glass/Laminate- 3/16" Heat Strengthened Glass/0.090" DuPont SGP Interlayer/3/16" Heat Strengthened Glass Frame: W-1829mm(72") H-2134mm(84") DLO: W-1708mm(67.25") H-2012mm(79.25")

SPECIFICATION	PRODUCT RATING
ASTM E1886-05/E1996-09 TAS 201/202/203-94 AAMA 506-11 AAMA/WDMA/CSA 101/1.S.2/A440-05/08/11	Design Pressure: ±3830 Pa (80 psf) Wind Zone 4-Missile Level D Large Missile Impact Rated A440-05 Rating: FW-C90 1829 x 2134 (72 x 84) A440-08/11 Rating: CW-PG100 1829 x 2134 (72 x 84)-FW Water Penetration Resistance Test Pressure: 718 Pa (15.0 psf)

Product Tested By: Element Materials Technology
Report No: ESP011976P-2/ESP011976P-2D
Expiration Date: January 31, 2027

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

**4794 George Washington Memorial Highway
Hayes, VA 23072**

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023