

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011284-R4
DATE: 09/25/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Eastern
CODE: 1783-1
REVISION DATE: 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Eastern Architectural Systems 16341 Domestic Avenue Ft. Myers, FL 33912	<p style="text-align: center;">Series "143" Vinyl Fin Frame or Equal Leg Frame Impact Rated Casement Window</p> <p style="text-align: center;">Configuration: X Glazing: IG-5/32" Annealed Glass/Laminate- 1/8" Annealed Glass/0.075" Interlayer (Eastman PVB)/ 1/8" Annealed Glass</p> <p>Frame: W-940mm(37") H-1930mm(76") Vent: W-895mm(35.25") H-1886mm(74.25")</p>

SPECIFICATION	PRODUCT RATING
<p style="text-align: center;">AAMA 506-08 ASTM E1886-05/E1996-06 TAS 201/202/203-94 AAMA/WDMA/CSA 101/I.S.2/A440-05</p>	<p style="text-align: center;">Design Pressure: +70/-70 psf Wind Zone 4-Missile Level D Large Missile Impact Rated C-C70 940 x 1930 (37 x 76)</p>

Product Tested By: Element Materials Technology
 Report No: ESP101311P-4/ESP10311P-5/ESP10311P-6/ESP10311P-7
 Expiration Date: **June 30, 2027**

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072

Tel: (804) 684-5124

Email: nami@namiinc.com

NOPC-03/30/2023