

# NOTICE OF PRODUCT CERTIFICATION




**CERTIFICATION NO:** NI010658.01-R4  
**DATE:** 05/24/2011  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Eastern  
**CODE:** 1783-1  
**REVISION DATE:** 10/16/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Eastern Architectural Systems</b> <b>10030 Bavaria Road</b> <b>Ft. Myers, FL 33913</b>	<b>Series "FWI 1000" Aluminum</b> <b>Impact Rated Horizontal Sliding Window</b>  Configuration: OX Glazing: Laminate-3/16" Heat Strengthened Glass/ 0.100" PVB Interlayer by Solutia/ 3/16" Heat Strengthened Glass  Frame: W-1883mm(74.13") H-1600mm(63") Panel: W-927mm(36.5") H-1549mm(61")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +100/-120 psf</b> <b>Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3751-1/W-2044  
Expiration Date: **February 28, 2027**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@naminc.com](mailto:nami@naminc.com)