

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006332.01-R2  
DATE: 12/12/2005  
CERTIFICATION PROGRAM: Structural  
COMPANY: JELD-WEN  
CODE: 1822-1  
REVISION DATE: 01/20/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>JELD-WEN</b> <b>3737 Lakeport Boulevard</b> <b>Klamath Falls, OR 97601</b>	<b>"Contours Premium Steel Wood-Edge Full Lite Fixed Sidelight" w/ODL Impact Glass or ODL Impact Allen Frame</b>  Configuration: O Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/ 0.090" Interlayer by Solutia/1/8" Annealed Glass  Frame: W-940mm(37")      H-2032mm(80") Panel: W-889mm(35")      H-2007mm(79") DLO: W-559mm(22")      H-1626mm(64")

SPECIFICATION	PRODUCT RATING
<b>TAS 201/202/203-94</b>	<b>Design Pressure: +80/-80 psf Large Missile Impact Rated</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-210-3194-1/SJW2011-73/W-1487/W-1560/W-1897/W-1905  
Expiration Date: September 30, 2029

Administrator's Signature: \_\_\_\_\_

A handwritten signature in black ink, appearing to be 'S. D.', is written over the signature line.

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122