

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI006332.04-R2
DATE: 12/12/2005
CERTIFICATION PROGRAM: Structural
COMPANY: JELD-WEN
CODE: 1822-1
REVISION DATE: 01/20/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
JELD-WEN 3737 Lakeport Boulevard Klamath Falls, OR 97601	"Contours Premium Steel Wood-Edge Full Lite Fixed Sidelight" w/ODL Impact Glass or ODL Impact Allen Frame Configuration: O Glazing: IG-1/8" Tempered Glass/ Laminate-1/8" Annealed Glass/ 0.090" Interlayer by Solutia/1/8" Annealed Glass Frame: W-946mm(37.25") H-2438mm(96") Panel: W-889mm(35") H-2413mm(95") DLO: W-521mm(20.5") H-1997mm(78.62")

SPECIFICATION	PRODUCT RATING
TAS 201/202/203-94	Design Pressure: +80/-80 psf Large Missile Impact Rated

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-210-3194-1/SJW2011-73/W-1487/W-1560/W-1897/W-1905
Expiration Date: September 30, 2029

Administrator's Signature: _____ 

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122