

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011057-R3
DATE: 04/10/2012
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 07/24/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan-Ya Plastics Corp. USA/Neuma Doors 8989 North Loop East Houston, TX 77029	“In-Swing Entrance Door W/Sidelites” Fiberglass In-Swing Side-Hinged Double Door w/Sidelites Configuration: OXXO Glazing: Insulating Glass (Tempered) Frame: W-3639mm(143.25") H-2096mm(82.5") Panel: W-876mm(34.5") H-2008mm(79.07") SLT: W-876mm(34.5") H-2008mm(79.07") DLO: W-635mm(25") H-1601mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08	Class R-PG60 3639 x 2096 (143 x 83)-LW SHD Design Pressure: ±2872 Pa (60 psf) Water Penetration Resistance Test Pressure: 287 Pa(6.0 psf)

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL 6844
Expiration Date: **January 31, 2032**

Administrator's Signature: _____


**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com