

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011058.02-R2
DATE: 03/13/2019
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya
CODE: 661-1
REVISION DATE: 09/15/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation USA 8989 North Loop East, Suite 800 Houston, TX 77029	Series "In-Swing Entrance Door with Sidelites" Fiberglass In-Swing Side Hinged Double Door w/Sidelites Configuration: OXXO Glazing: Insulating Glass(Tempered & Annealed) Frame: W-3639mm(143.25) H-2096mm(82.50") Panel: W-876mm(34.50") H-2008mm(79.07") Sidelite: W-876mm(34.50") H-2008mm(79.07") DLO: W-635mm(25.00") H-1601mm(63.00")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-05	Class R-PG40 3639 x 2096 (144 x 83)-LW SHD Design Pressure: 1915 Pa (40 psf) Water Penetration Resistance Test Pressure: 287 Pa (6.00 psf) Qualifies Configurations: O/X/OX/XO/OXX/XXO/OXO/OXXO

Product Tested By: Fenestration Testing Laboratory, Inc.
Report No: FTL 6719/W-1549
Expiration Date: April 30, 2025

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122