

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI011074.02-R2  
**DATE:** 03/13/2019  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Nan Ya Plastics  
**CODE:** 661-1  
**REVISION DATE:** 08/07/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit [www.namicertification.com](http://www.namicertification.com). NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Nan Ya Plastics Corp. USA/ Neuma Doors</b> <b>8989 North Loop East</b> <b>Houston, TX 77029</b>	<b>“Out-Swing Entrance Door w/Sidelites”</b> <b>Fiberglass Glazed Side-Hinged Doors</b> <b>w/Glazed Fixed Panels</b>  Configuration: OXXO Glazing: Insulating Glass (Tempered/Annealed) Frame: W-3635mm(143.13") H-2096mm(82.5") Panel: W-876mm(34.5") H-2040mm(80.32") DLO: W-635mm(25") H-1601mm(63")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b>	<b>Class R-PG65 3635 X 2096 (144 x 83)-SHD</b> Qualifies Configurations: O/X/OX/XO/OXO/XX/OXX/XXO/OXXO

Product Tested By: Fenestration Testing Laboratory, Inc.  
Report No: FTL # 6716  
Expiration Date: **April 30, 2032**

Administrator's Signature: \_\_\_\_\_  


**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**  
4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Email: [nami@namiinc.com](mailto:nami@namiinc.com)