

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011687-R6
DATE: 10/22/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Nan Ya Plastics
CODE: 661-1
REVISION DATE: 07/24/2023

This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. To affirm the certification status, please visit www.namicertification.com. NAMI is accredited to the ISO/IEC 17065 by the ANSI National Accreditation Board (ANAB) and the Standards Council of Canada (SCC).

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Nan Ya Plastics Corporation U.S.A. 8989 North Loop East Houston, TX 77029	“Out-Swing Entrance Door w/Sidelites” Fiberglass Out-Swing Side-Hinged Door w/Sidelites Configuration: OXXO Glazing: IG-1/8" Tempered Glass/Laminate-1/8" Annealed Glass/0.090" DuPont Butacite PVB/1/8" Annealed Glass Frame: W-3632mm(143") H-2096mm(82.5") Panel: W-876mm(34.50") H-2040mm(80.31") DLO: W-635mm(25") H-1600mm(63")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-08 ASTM E1886-05/1996-05 AAMA 506-08	Class R-PG50 3632 x 2096 (143 x 83)-SHD Design Pressure: 2400 Pa (50 psf) Wind Zone 4-Missile Level D Water Penetration Resistance Test Pressure: 503 Pa (10.5 psf)

Product Tested By: Fenestration Testing Laboratories
Report No: FTL-6757/FTL-6492
Expiration Date: **January 31, 2032**

Administrator's Signature: _____

A handwritten signature in black ink, appearing to be "MD", written over a horizontal line.

**NATIONAL ACCREDITATION AND
MANAGEMENT INSTITUTE, INC.**
4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
nami@namiinc.com