

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010089-R5  
DATE: 01/18/2010  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 06/25/2020

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>"1500 Vinyl Collection (No Fin)"</b> <b>Vinyl Out-Swing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-902mm(35.5") H-1816mm(71.5") Vent: W-854mm(33.6") H-1768mm(69.6")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>C-LC45 902 x 1816 (36 x 72)</b> <b>Design Pressure: 2155 Pa (45 psf)</b> <b>Negative Design Pressure: 2155 Pa (45 psf)</b> <b>Water Penetration Resistance Test Pressure: 431 Pa (9.0 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12326-1  
Expiration Date: March 31, 2025

A handwritten signature in black ink, appearing to be 'S.M.D.', written over a horizontal line.

Administrator's Signature: \_\_\_\_\_

**NATIONAL ACCREDITATION AND  
MANAGEMENT INSTITUTE, INC.**

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122