

# NOTICE OF PRODUCT CERTIFICATION



**CERTIFICATION NO:** NI010441-R5  
**DATE:** 12/27/2010  
**CERTIFICATION PROGRAM:** Structural  
**COMPANY:** Ply Gem  
**CODE:** 1408-1  
**REVISION DATE:** 03/08/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> <b>433 North Main Street</b> <b>Rocky Mount, VA 24151</b>	<b>Series "Builder Series 1140 Casement"</b> <b>Vinyl Out-Swing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-914mm(36") H-1829mm(72") Vent: W-857mm(33.75") H-1772mm(69.75")

SPECIFICATION	PRODUCT RATING
<b>AAMA/WDMA/CSA 101/I.S.2/A440-17</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-11</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-08</b> <b>AAMA/WDMA/CSA 101/I.S.2/A440-05</b>	<b>Class LC-PG45 914 x 1829 (36 x 72)-C</b> <b>C-LC45 914 x 1829 (36 x 72)</b> <b>Design Pressure: 2153 Pa (45 psf)</b> <b>Negative Design Pressure: 2153 Pa (45 psf)</b> <b>Water Penetration Resistance Test Pressure: 575 Pa (12.0 psf)</b>

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-12901-1/W-1988  
Expiration Date: August 31, 2025

Administrator's Signature: \_\_\_\_\_  


## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway  
Hayes, VA 23072  
Tel: (804) 684-5124  
Fax: (804) 684-5122