

# NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI010527-R4  
DATE: 02/12/2011  
CERTIFICATION PROGRAM: Structural  
COMPANY: Ply Gem  
CODE: 1408-1  
REVISION DATE: 11/02/2021

To verify that the "Notice of Product Certification" is valid, please visit [www.NAMICertification.com](http://www.NAMICertification.com) to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
<b>Ply Gem Window Group</b> 433 North Main Street Rocky Mount, VA 24151	<b>"1500 Vinyl Collection/Classic/5000"</b> <b>Vinyl Outswing Casement Window</b>  Configuration: X Glazing: Insulating Glass (Annealed)  Frame: W-902mm(35.5") H-1816mm(71.5") Vent: W-854mm(33.62") H-1767mm(69.56")

SPECIFICATION	PRODUCT RATING
AAMA/WDMA/CSA 101/I.S.2/A440-17 AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08 AAMA/WDMA/CSA 101/I.S.2/A440-05	<b>Class LC-PG50 902 x 1816 (36 x 72)-C</b> <b>C-LC50 902 x 1816 (36 x 72)</b> <b>Design Pressure: ±2394 Pa (±50 psf)</b> Water Penetration Resistance Test Pressure: 467 Pa (9.75 psf)

Product Tested By: National Certified Testing Laboratories  
Report No: NCTL-110-13615-1/W-2010  
Expiration Date: **January 31, 2026**

Administrator's Signature: \_\_\_\_\_

## NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway

Hayes, VA 23072

Tel: (804) 684-5124

Fax: (804) 684-5122