

NOTICE OF PRODUCT CERTIFICATION



CERTIFICATION NO: NI011409-R7
DATE: 01/29/2013
CERTIFICATION PROGRAM: Structural
COMPANY: Ply Gem
CODE: 1408-1
REVISION DATE: 07/06/2020

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

COMPANY NAME AND ADDRESS	PRODUCT DESCRIPTION
Ply Gem Window Group 433 North Main Street Rocky Mount, VA 24151	"1500 Vinyl Collection/Classic" Vinyl Casement Window Configuration: X Glazing: IG-1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Eastman Interlayer/1/8" Annealed Glass or 1/8" Annealed Glass/Laminate-1/8" Annealed Glass/0.090" Kuraray Interlayer/1/8" Annealed Glass Frame: W-902mm(35.5") H-1816mm(71.5") Vent: W-854mm(33.62") H-1768mm(69.63")

SPECIFICATION	PRODUCT RATING
AAMA 506-06 ASTM E1886-05/E1996-02/06/09 AAMA/WDMA/CSA 101/I.S.2/A440-05/08/11	Design Pressure: +50/-60 psf Wind Zone 3-Missile Level D Individual Rating: Class LC-PG50 914 x 1829 (36 x 72)-C Negative Design Pressure: 2880 Pa (60 psf) Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf)

Product Tested By: National Certified Testing Laboratories
Report No: NCTL-110-15390-1
Expiration Date: March 31, 2025

A handwritten signature in black ink, appearing to be 'Shi' or similar, written over a horizontal line.

Administrator's Signature: _____

NATIONAL ACCREDITATION AND MANAGEMENT INSTITUTE, INC.

4794 George Washington Memorial Highway
Hayes, VA 23072
Tel: (804) 684-5124
Fax: (804) 684-5122