

NOTICE OF PRODUCT CERTIFICATION



| | |
|-------------------------------|-----------------------|
| CERTIFICATION NO: | <u>NI014061.01-R1</u> |
| DATE: | <u>09/10/2018</u> |
| CERTIFICATION PROGRAM: | <u>Structural</u> |
| COMPANY: | <u>Ply Gem</u> |
| CODE: | <u>1408-1</u> |
| REVISION DATE: | <u>02/03/2022</u> |

To verify that the "Notice of Product Certification" is valid, please visit www.NAMICertification.com to assure that the product is active and currently listed. This certification represents product conformity to the applicable specification and that certification criteria has been satisfied. A NAMI approved certification label must be applied to the product to claim certification status. Please review and advise NAMI if any corrections are required to this document.

| COMPANY NAME AND ADDRESS | PRODUCT DESCRIPTION |
|--|---|
| <p>Ply Gem Window Group</p> <p>433 North Main Street</p> <p>Rocky Mount, VA 24151</p> | <p style="text-align: center;">Series "Mira" Outswing</p> <p style="text-align: center;">Aluminum Clad Wood Casement</p> <p style="text-align: center;">Configuration: X Glazing: IG-1/8" Annealed Glass/1/8" Annealed Glass/0.090" Eastman Saflex PVB Interlayer/1/8" Annealed Glass</p> <p>Frame: W-914mm(36") H-1829mm(72")</p> <p>Vent: W-870mm(34.25") H-1784mm(70.25")</p> <p>DLO: W-765mm(30.13") H-1680mm(66.13")</p> |

| SPECIFICATION | PRODUCT RATING |
|--|---|
| <p style="text-align: center;">AAMA 506-06/08/11/16 ASTM E1886-02/04/05/13a ASTM E1996-02/04/06/09/12a/14a AAMA/WDMA/CSA 101/I.S.2/A440-11 AAMA/WDMA/CSA 101/I.S.2/A440-08</p> | <p style="text-align: center;">Wind Zone 3 - Missile Level D</p> <p style="text-align: center;">Class LC-PG60 914 x 1829* (36 x 72*)-C</p> <p style="text-align: center;">Design Pressure: +2880 Pa (60 psf)</p> <p style="text-align: center;">Water Penetration Resistance Test Pressure: 440 Pa (9.19 psf) Canadian Air Infiltration/Exfiltration Level: A3</p> |

Product Tested By: National Certified Testing Laboratories
 Report No: NCTL-110-21376-1/NCTL-110-20986-1
 Expiration Date: May 31, 2026

Administrator's Signature: _____

**NATIONAL ACCREDITATION AND
 MANAGEMENT INSTITUTE, INC.**
 4794 George Washington Memorial Highway
 Hayes, VA 23072
 Tel: (804) 684-5124
 Email: nami@namiinc.com